

Coleman Creek Consulting, Inc.

## **DRINKING WATER LEAD SAMPLING**

OF

**HENLEY HIGH SCHOOL**

**8245 HWY. 39, KLAMATH FALLS, OREGON**

FOR

**KLAMATH COUNTY SCHOOL DISTRICT**

### **INTRODUCTION**


Coleman Creek Consulting, Inc. (CCC) was retained by Klamath County School District (KCS D) to perform representative lead drinking water sampling of Henley High School at the above address. The purpose of the lead drinking water sampling was to determine the concentration of lead in representative drinking water sources and compare with regulatory standards. In 2017, Education Service Districts were required to adopt a Healthy and Safe Schools Plan, including provisions for testing and reducing exposure to elevated levels of lead in water used for drinking and food preparation.

### **LEAD DRINKING WATER SAMPLING REQUIREMENTS**

Guidelines for sampling lead in water were established by the Oregon Health Authority. Water sampling is to occur after water sits overnight in the pipes without being used, and must be sampled after a day occupied by students or building occupants. All water sources are to be sampled, with the exception of water used for heating, sanitation, irrigation, and science sinks for grades 6 and up with non-potable water signs. Initial testing is required to be performed by 2020, and every 6 years thereafter, according to a testing schedule determined by the Oregon Department of Education.

### **SAMPLE LOCATION DETERMINATION/SAMPLE PREP**

David W. Fawcett of CCC contacted Mark Kasper, Head Custodian at Henley High School, and discussed the objectives of the lead drinking water program. Mr. Kasper reviewed the School buildings for water sources and identified by type on a building floor plan. Mr. Fawcett and Mr. Kasper discussed the drinking water sources by phone, and Mr. Fawcett created a Site Sample Record Sheet describing each drinking water source by type and location. Mr. Fawcett identified each source by number (1-89), and identified each source number on a floor plan diagram of the school buildings. Mr. Fawcett delivered the following sampling materials to Mr. Kasper January 15, 2025: Numbered sample containers, Site Sample Record Sheet filled out with Sample Number, Sample Type, and Location. Mr. Kasper was instructed in proper sampling technique, including sampling prior to water system use by other school occupants, fill sample container immediately from faucet opening, and recording time of water sampling on the Site Sample Record Sheets (pages 3-7).



# Coleman Creek Consulting, Inc.

## DRINKING WATER SAMPLING

Mr. Kasper collected lead drinking water samples from the drinking water sources identified in Henley High School January 16, 2025. See Site Sample Record Sheets (pages 3-7) for a description of the drinking water sources sampled. Proposed drinking water sample locations at Samples #23, #26, #28 and #31 were determined to be non-functional or non-existent at the time of sampling, and account for the missing sample numbers on both the Site Sample Record Sheet and Sample Location Diagram. See Drinking Water Sample Location Diagram in Appendix A for a visual review of all drinking water sample locations. The drinking water samples were collected in the early morning, ensuring that the sample source had not been in use since the previous day. The samples were placed in a cooler. Mr. Fawcett picked up the samples collected by Mr. Kasper January 16, 2025, and transported to Neilson Research Corporation in Medford, Oregon.

## DRINKING WATER LEAD RESULTS AND TESTING SUMMARY SHEETS

The eighty-five (85) drinking water samples collected were analyzed for lead using EPA Method 200.8. See Neilson Research Corporation Analytical Report in Appendix B. Drinking Water Testing Summary Sheets (pages 8-11) indicate the lead in drinking water concentrations for the sixty-seven (85) samples collected from Henley High School were reported ranging from <0.5 to 6.07 parts per billion (ppb), with the exception of Sample #39, Room 211 back sink faucet, reported with 21.7 ppb lead, and Sample #65, Room 208 lab sink at teacher desk reported with 27 ppb lead.


## CONCLUSIONS

Eighty-five (85) drinking water samples were collected from drinking water sources at Henley High School prior to use that day by building occupants, and after a day the facility was occupied. The lead concentrations reported were all below the 15 ppb lead action level in water, with the exception of Sample #39, reported with 21.7 ppb lead, and Sample #65 reported with 27 ppb lead. Both faucets reported with elevated lead concentrations were removed from service and the sinks deleted.

## RECOMMENDATIONS

Coleman Creek Consulting, Inc. recommends continuing the lead drinking water sampling schedule in the future. Coleman Creek Consulting, Inc. appreciates the opportunity to continue to perform environmental sampling and consulting services to Klamath County School District.

David W. Fawcett  
Director of Consulting Services



# Coleman Creek Consulting, Inc.


## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME
24-163G.1	DW	Kitchen Bath Sink Faucet	0509
24-163G.2	DW	Kitchen Left Sink Faucet	0511
24-163G.3	DW	Kitchen Right Sink Faucet	0513
24-163G.4	DW	Kitchen Handwash Sink Faucet	0515
24-163G.5	DW	Cafeteria Drinking Fountain	0517
24-163G.6	DW	Cafeteria Drinking Fountain Bottle Fill	0517
24-163G.7	DW	Back of Main Gym Drinking Fountain	0522
24-163G.8	DW	Main Gym Corner Drinking Fountain	0524
24-163G.9	DW	Main Gym Corner Drinking Fountain Bottle Fill	0526
24-163G.10	DW	Gym Concession Left Sink Faucet	0528
24-163G.11	DW	Boy's Gym Restroom Left Sink Faucet	0529
24-163G.12	DW	Boy's Gym Restroom Left Middle Sink Faucet	0529
24-163G.13	DW	Boy's Gym Restroom Right Middle Sink Faucet	0530
24-163G.14	DW	Boy's Gym Restroom Right Sink Faucet	0530
24-163G.15	DW	Hall Drinking Fountain at Gym/Boy's Bath	0531
24-163G.16	DW	Girl's Gym Restroom Left Sink Faucet	0533
24-163G.17	DW	Girl's Gym Restroom Left Middle Sink Faucet	0533
24-163G.18	DW	Girl's Gym Restroom Right Middle Faucet	0534
24-163G.19	DW	Girl's Gym Restroom Right Sink Faucet	0534
24-163G.20	DW	Hall Drinking Fountain at Gym/Girl's Bath	0535

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.

## DRINKING WATER SITE SAMPLE RECORD SHEET


BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME
24-163G.21	DW	Hall Drinking Fountain Bottle Fill at Girl's Bath	0535
24-163G.22	DW	Boy's Locker Left Sink Faucet	0556
24-163G.24	DW	Boy's Locker Right Sink Faucet	0555
24-163G.25	DW	Boy's Locker Drinking Fountain	0557
24-163G.27	DW	Girl's Locker Left Sink Faucet	0558
24-163G.29	DW	Girl's Locker Right Sink Faucet	0558
24-163G.30	DW	Girl's Locker Drinking Fountain	0558
24-163G.32	DW	Small Gym Drinking Fountain	0559
24-163G.33	DW	Small Gym Drinking Fountain Bottle Fill	0559
24-163G.34	DW	Shop Left Sink Faucet	0603
24-163G.35	DW	Shop Middle Sink Faucet	0603
24-163G.36	DW	Shop Right Sink Faucet	0603
24-163G.37	DW	Room 212 Sink Faucet	0605
24-163G.38	DW	Room 211 Front Sink Faucet	0607
24-163G.39	DW	Room 211 Back Sink Faucet	0607
24-163G.40	DW	Boiler Room Sink Faucet	0608

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle

Proposed Drinking water sources at Sample #'s 23, 26, 28, and 31 either did not exist, or were not operational at the time of sampling, therefor no samples were collected.



# Coleman Creek Consulting, Inc.


## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME
24-163G.41	DW	Staff Hall Bath at Room 112 Left Sink Faucet	0611
24-163G.42	DW	Staff Hall Bath at Room 112 Middle Sink Faucet	0612
24-163G.43	DW	Staff Hall Bath at Room 112 Right Sink Faucet	0613
24-163G.44	DW	Girl's Hall Bath at Room 112 Left Sink Faucet	0614
24-163G.45	DW	Girl's Hall Bath at Room 112 LM Sink Faucet	0614
24-163G.46	DW	Girl's Hall Bath at Room 112 RM Sink Faucet	0616
24-163G.47	DW	Girl's Hall Bath at Room 112 Right Sink Faucet	0617
24-163G.48	DW	Hall Drinking Fountain at Room 112	0618
24-163G.49	DW	Room 209 Sink Faucet	0621
24-163G.50	DW	Chemical Room at Room 209, Left Sink Faucet	0620
24-163G.51	DW	Chemical Room at Room 209, Right Sink Faucet	0620
24-163G.52	DW	Room 210 Left Lab Sink Faucet at Door	0615
24-163G.53	DW	Room 210 Middle Lab Sink Faucet at Door	0616
24-163G.54	DW	Room 210 Right Lab Sink Faucet at Door	0616
24-163G.55	DW	Room 210 Left Lab Sink Faucet at Courtyard	0616
24-163G.56	DW	Room 210 Middle Lab Sink Faucet at Courtyard	0616
24-163G.57	DW	Room 210 Right Lab Sink Faucet at Courtyard	0616
24-163G.58	DW	Room 210 Lab Sink Faucet at Teacher Desk	0616
24-163G.59	DW	Room 208 Left Lab Sink Faucet at Door	0626
24-163G.60	DW	Room 208 Right Lab Sink Faucet at Door	0626

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.


## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME
24-163G.61	DW	Room 208 Left Lab Sink Faucet at Hall Wall	0628
24-163G.62	DW	Room 208 Right Lab Sink Faucet at Hall Wall	0628
24-163G.63	DW	Room 208 Left Lab Sink Faucet at Courtyard Wall	0628
24-163G.64	DW	Room 208 Right Lab Sink Faucet at Courtyard	0628
24-163G.65	DW	Room 208 Right Lab Sink Faucet at Teacher Desk	0628
24-163G.66	DW	Storage Room Sink Faucet at Room 208	0628
24-163G.67	DW	Room 207 Left Lab Sink Faucet at Door	0630
24-163G.68	DW	Room 207 Right Lab Sink Faucet at Door	0630
24-163G.69	DW	Room 207 Lab Sink Faucet at Teacher Desk	0631
24-163G.70	DW	Room 207 Left Lab Sink Faucet at Courtyard Wall	0632
24-163G.71	DW	Room 207 Right Lab Sink Faucet at Courtyard	0632
24-163G.72	DW	Room 207 Left Lab Sink Faucet at Right Wall	0632
24-163G.73	DW	Room 207 Right Lab Sink Faucet at Right Wall	0633
24-163G.74	DW	Room 205 Sink Faucet	0635
24-163G.75	DW	Storage Room Sink Faucet at Room 205	0635
24-163G.76	DW	Room 206 Sink Faucet	0637
24-163G.77	DW	Office Staff Room Sink Faucet	0640
24-163G.78	DW	Hall Drinking Fountain at Room 100	0641
24-163G.79	DW	Girl's Bath Left Sink Faucet at Room 100	0648
24-163G.80	DW	Girl's Bath Left Middle Sink Faucet at Room 100	0648

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.


## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME
24-163G.81	DW	Girl's Bath Right Middle Sink Faucet at Room 100	0648
24-163G.82	DW	Girl's Bath Right Sink Faucet at Room 100	0648
24-163G.83	DW	Boy's Bath Left Sink Faucet at Room 100	0650
24-163G.84	DW	Boy's Bath Middle Sink Faucet at Room 100	0650
24-163G.85	DW	Boy's Bath Right Sink Faucet at Room 100	0650
24-163G.86	DW	Library Side Room Sink Faucet	0655
24-163G.87	DW	Room 405 (Portable) Left Sink Faucet	0700
24-163G.88	DW	Room 405 (Portable) Middle Sink Faucet	0700
24-163G.89	DW	Room 405 (Portable) Right Sink Faucet	0700

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.

## DRINKING WATER TESTING SUMMARY SHEET


DISTRICT NAME: Klamath County School District  
DISTRICT ID#: 467  
SCHOOL NAME: Henley High School  
BUILDING NAME: Henley High School  
BUILDING ID#: 20571800

Sample Number	Fixture Location/ Description	Fixture ID#	Test Date	Test Result (ppb)	# Retest	Final Result (ppb)
25-163G.1	Kitchen Bath Sink	20571800-001KF	01-16-25	<0.515		<0.515
25-163G.2	Kitchen Left Sink	20571800-002KF	01-16-25	1.46		1.46
25-163G.3	Kitchen Right Sink	20571800-003KF	01-16-25	0.958		0.958
25-163G.4	Kitchen Handwash Sink	20571800-004KF	01-16-25	<0.515		<0.515
25-163G.5	Cafeteria Fountain	20571800-005DW	01-16-25	<0.515		<0.515
25-163G.6	Cafeteria Bottle Fill	20571800-006WB	01-16-25	<0.515		<0.515
25-163G.7	Back of Main Gym Fountain	20571800-007DW	01-16-25	1.74		1.74
25-163G.8	Main Gym Corner Fountain	20571800-008DW	01-16-25	<0.515		<0.515
25-163G.9	Main Gym Corner Bottle Fill	20571800-009WB	01-16-25	<0.515		<0.515
25-163G.10	Gym Concession Left Sink	20571800-010SF	01-16-25	0.636		0.636
25-163G.11	Boy's Gym Bath Left Sink	20571800-011BF	01-16-25	<0.515		<0.515
25-163G.12	Boy's Gym Bath Left Middle Sink	20571800-012BF	01-16-25	<0.515		<0.515
25-163G.13	Boy's Gym Bath Right Middle Sink	20571800-013BF	01-16-25	<0.515		<0.515
25-163G.14	Boy's Gym Bath Right Sink	20571800-014BF	01-16-25	<0.515		<0.515
25-163G.15	Hall Fountain at Gym/Boy's Bath	20571800-015DW	01-16-25	<0.515		<0.515
25-163G.16	Girl's Gym Bath Left Sink	20571800-016BF	01-16-25	<0.515		<0.515
25-163G.17	Girl's Gym Bath Left Middle Sink	20571800-017BF	01-16-25	<0.515		<0.515
25-163G.18	Girl's Gym Bath Right Middle	20571800-018BF	01-16-25	<0.515		<0.515
25-163G.19	Girl's Gym Bath Right Sink	20571800-019BF	01-16-25	<0.515		<0.515
25-163G.20	Hall Fountain at Gym/Girl's Bath	20571800-020DW	01-16-25	<0.515		<0.515
25-163G.21	Hall Bottle Fill at Girl's Bath	20571800-021WB	01-16-25	<0.515		<0.515
25-163G.22	Boy's Locker Left Sink	20571800-022BF	01-16-25	<0.515		<0.515
25-163G.24	Boy's Locker Right Sink	20571800-024BF	01-16-25	<0.515		<0.515
25-163G.25	Boy's Locker Fountain	20571800-025DW	01-16-25	<0.515		<0.515
25-163G.27	Girl's Locker Left Sink	20571800-027BF	01-16-25	0.621		0.621
25-163G.29	Girl's Locker Right Sink	20571800-029BF	01-16-25	2.49		2.49
25-163G.30	Girl's Locker Fountain	20571800-030DW	01-16-25	1.21		1.21

Fixture ID Coding:

**Bold Indicates Test Result >15 ppb**

DW = Drinking Water Fountain WC = Water Cooler WB = Water Bottle Filler  
CF = Classroom Faucet BF = Bathroom Faucet SF = Staff/Office Faucet  
KF = Kitchen/Food Prep OS = Outside Spigot OT = Other (Specify)



# Coleman Creek Consulting, Inc.

## DRINKING WATER TESTING SUMMARY SHEET


DISTRICT NAME: Klamath County School District  
DISTRICT ID#: 467  
SCHOOL NAME: Henley High School  
BUILDING NAME: Henley High School  
BUILDING ID#: 20571800

Sample Number	Fixture Location/ Description	Fixture ID#	Test Date	Test Result (ppb)	# Retest	Final Result (ppb)
25-163G.32	Small Gym Drinking Fountain	20571800-032DW	01-16-25	<0.515		<0.515
25-163G.33	Small Gym Fountain Bottle Fill	20571800-033WB	01-16-25	<0.515		<0.515
25-163G.34	Shop Left Sink	20571800-034CF	01-16-25	1.03		1.03
25-163G.35	Shop Middle Sink	20571800-035CF	01-16-25	1.45		1.45
25-163G.36	Shop Right Sink	20571800-036CF	01-16-25	2.13		2.13
25-163G.37	Room 212 Sink	20571800-037CF	01-16-25	3.45		3.45
25-163G.38	Room 211 Front Sink	20571800-038CF	01-16-25	2.93		2.93
25-163G.39	Room 211 Back Sink	20571800-039CF	01-16-25	<b>21.7</b>	<b>Faucet</b>	<b>Deleted</b>
25-163G.40	Boiler Room Sink	20571800-040SF	01-16-25	0.616		0.616
25-163G.41	Staff Hall Bath at Room 112 Left Sink	20571800-041BF	01-16-25	<0.515		<0.515
25-163G.42	Staff Hall Bath at Room 112 M Sink	20571800-042BF	01-16-25	0.82		0.82
25-163G.43	Staff Hall Bath at Room 112 R Sink	20571800-043BF	01-16-25	0.643		0.643
25-163G.44	Girl's Bath at Room 112 Left Sink	20571800-044BF	01-16-25	<0.515		<0.515
25-163G.45	Girl's Bath at Room 112 LM Sink	20571800-045BF	01-16-25	<0.515		<0.515
25-163G.46	Girl's Bath at Room 112 RM Sink	20571800-046BF	01-16-25	<0.515		<0.515
25-163G.47	Girl's Bath at Room 112 Right Sink	20571800-047BF	01-16-25	<0.515		<0.515
25-163G.48	Hall Fountain at Room 112	20571800-048DW	01-16-25	<0.515		<0.515
25-163G.49	Room 209 Sink	20571800-049CF	01-16-25	1.51		1.51
25-163G.50	Chemical Room, Left Sink	20571800-050SF	01-16-25	<0.515		<0.515
25-163G.51	Chemical Room, Right Sink	20571800-051SF	01-16-25	<0.515		<0.515
25-163G.52	Room 210 Left Lab Sink at Door	20571800-052CF	01-16-25	0.511		0.511
25-163G.53	Room 210 Middle Lab Sink at Door	20571800-053CF	01-16-25	<0.515		<0.515
25-163G.54	Room 210 Right Lab Sink at Door	20571800-054CF	01-16-25	<0.515		<0.515
25-163G.55	Room 210 Left Lab Sink at Courtyard	20571800-055CF	01-16-25	<0.515		<0.515
25-163G.56	Room 210 M Lab Sink at Courtyard	20571800-056CF	01-16-25	1.06		1.06
25-163G.57	Room 210 R Lab Sink at Courtyard	20571800-057CF	01-16-25	<0.515		<0.515
25-163G.58	Room 210 Lab Sink at Teacher Desk	20571800-058CF	01-16-25	1.95		1.95
25-163G.59	Room 208 Left Lab Sink at Door	20571800-059CF	01-16-25	1.5		1.5
25-163G.60	Room 208 Right Lab Sink at Door	20571800-060CF	01-16-25	<0.515		<0.515

Fixture ID Coding:

**Bold Indicates Test Result >15 ppb**

DW = Drinking Water Fountain WC = Water Cooler WB = Water Bottle Filler  
CF = Classroom Faucet BF = Bathroom Faucet SF = Staff/Office Faucet  
KF = Kitchen/Food Prep OS = Outside Spigot OT = Other (Specify)



# Coleman Creek Consulting, Inc.

## DRINKING WATER TESTING SUMMARY SHEET


DISTRICT NAME: Klamath County School District  
DISTRICT ID#: 467  
SCHOOL NAME: Henley High School  
BUILDING NAME: Henley High School  
BUILDING ID#: 20571800

Sample Number	Fixture Location/ Description	Fixture ID#	Test Date	Test Result (ppb)	# Retest	Final Result (ppb)
25-163G.61	Room 208 Left Lab Sink at Hall Wall	20571800-061CF	01-16-25	<0.515		<0.515
25-163G.62	Room 208 Right Lab Sink at Hall	20571800-062CF	01-16-25	<0.515		<0.515
25-163G.63	Room 208 L Lab Sink at Courtyard	20571800-063CF	01-16-25	<0.515		<0.515
25-163G.64	Room 208 R Lab Sink at Courtyard	20571800-064CF	01-16-25	3.94		3.94
25-163G.65	Room 208 Right Lab Sink at Teacher	20571800-065CF	01-16-25	<b>27</b>	<b>Faucet</b>	<b>Deleted</b>
25-163G.66	Storage Room Sink at Room 208	20571800-066SF	01-16-25	0.526		0.526
25-163G.67	Room 207 Left Lab Sink at Door	20571800-067CF	01-16-25	0.877		0.877
25-163G.68	Room 207 Right Lab Sink at Door	20571800-068CF	01-16-25	<0.515		<0.515
25-163G.69	Room 207 Lab Sink at Teacher Desk	20571800-069CF	01-16-25	11.2		11.2
25-163G.70	Room 207 L Lab Sink at Courtyard	20571800-070CF	01-16-25	1.32		1.32
25-163G.71	Room 207 R Lab Sink at Courtyard	20571800-071CF	01-16-25	6.07		6.07
25-163G.72	Room 207 L Lab Sink at Right Wall	20571800-072CF	01-16-25	4.23		4.23
25-163G.73	Room 207 R Lab Sink at Right Wall	20571800-073CF	01-16-25	1.2		1.2
25-163G.74	Room 205 Sink	20571800-074CF	01-16-25	1.06		1.06
25-163G.75	Storage Room Sink at Room 205	20571800-075SF	01-16-25	<0.515		<0.515
25-163G.76	Room 206 Sink	20571800-076CF	01-16-25	<0.515		<0.515
25-163G.77	Office Staff Room Sink	20571800-077SF	01-16-25	1.33		1.33
25-163G.78	Hall Fountain at Room 100	20571800-078DW	01-16-25	<0.515		<0.515
25-163G.79	Girl's Bath Left Sink at Room 100	20571800-079BF	01-16-25	0.831		0.831
25-163G.80	Girl's Bath LM Sink at Room 100	20571800-080BF	01-16-25	<0.515		<0.515
25-163G.81	Girl's Bath RM Sink at Room 100	20571800-081BF	01-16-25	<0.515		<0.515
25-163G.82	Girl's Bath Right Sink at Room 100	20571800-082BF	01-16-25	0.645		0.645
25-163G.83	Boy's Bath Left Sink at Room 100	20571800-083BF	01-16-25	<0.515		<0.515
25-163G.84	Boy's Bath Middle Sink at Room 100	20571800-084BF	01-16-25	<0.515		<0.515
25-163G.85	Boy's Bath Right Sink at Room 100	20571800-085BF	01-16-25	<0.515		<0.515
25-163G.86	Library Side Room Sink	20571800-086SF	01-16-25	<0.515		<0.515

Fixture ID Coding:

**Bold Indicates Test Result >15 ppb**

DW = Drinking Water Fountain WC = Water Cooler WB = Water Bottle Filler  
CF = Classroom Faucet BF = Bathroom Faucet SF = Staff/Office Faucet  
KF = Kitchen/Food Prep OS = Outside Spigot OT = Other (Specify)



# Coleman Creek Consulting, Inc.

## DRINKING WATER TESTING SUMMARY SHEET

DISTRICT NAME: Klamath County School District  
DISTRICT ID#: 467  
SCHOOL NAME: Henley High School  
BUILDING NAME: Portable #1  
BUILDING ID#: 20571803

Sample Number	Fixture Location/ Description	Fixture ID#	Test Date	Test Result (ppb)	# Retest	Final Result (ppb)
25-163G.87	Room 405 (Portable) Left Sink	20571803-087CF	01-16-25	0.824		0.824
25-163G.88	Room 405 (Portable) Middle Sink	20571803-088CF	01-16-25	0.576		0.576
25-163G.89	Room 405 (Portable) Right Sink	20571803-089CF	01-16-25	<0.515		<0.515

Fixture ID Coding:

**Bold Indicates Test Result >15 ppb**

DW = Drinking Water Fountain WC = Water Cooler WB = Water Bottle Filler  
CF = Classroom Faucet BF = Bathroom Faucet SF = Staff/Office Faucet  
KF = Kitchen/Food Prep OS = Outside Spigot OT = Other (Specify)

**APPENDIX A**

**DRINKING WATER SAMPLE LOCATION  
DIAGRAM**



## **APPENDIX B**

### **NEILSON RESEARCH CORPORATION ANALYTICAL REPORT**



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

January 29, 2025

Dave Fawcett  
Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520  
TEL: (541) 535-7108  
FAX (541) 535-8795

RE: 24-163G Henley HS

Order No.: 25010677

Dear Dave Fawcett:

Neilson Research Corporation received 85 sample(s) on 1/16/2025 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501



Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 25010677  
Date: 1/29/2025

---

**CLIENT:** Coleman Creek Consulting  
**Project:** 24-163G Henley HS

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-01 Client Sample ID: 24-163.G1  
Collection Date: 1/16/2025 5:09:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Kitchen RR Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-02 Client Sample ID: 24-163.G2  
Collection Date: 1/16/2025 5:11:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Kitchen Sink L

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.46		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-03 Client Sample ID: 24-163.G3  
Collection Date: 1/16/2025 5:13:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Kitchen Sink R

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.958		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-04 Client Sample ID: 24-163.G4  
Collection Date: 1/16/2025 5:13:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Kitchen Handwash

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-05 Client Sample ID: 24-163.G5  
Collection Date: 1/16/2025 5:17:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Cafeteria DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-06 Client Sample ID: 24-163.G6  
Collection Date: 1/16/2025 5:17:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Cafeteria DF Bottle Fill

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.512	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-07 Client Sample ID: 24-163.G7  
Collection Date: 1/16/2025 5:22:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Back of Main Gym DF

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.74		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-08 Client Sample ID: 24-163.G8  
Collection Date: 1/16/2025 5:24:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Main Gym Corner DF

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-09 Client Sample ID: 24-163.G9  
Collection Date: 1/16/2025 5:26:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Main Gym Corner DF Bottle Fill

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-10 Client Sample ID: 24-163.G10  
Collection Date: 1/16/2025 5:28:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Gym Concession L Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.636		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-11 Client Sample ID: 24-163.G11  
Collection Date: 1/16/2025 5:29:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's Gym RR L Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-12 Client Sample ID: 24-163.G12  
Collection Date: 1/16/2025 5:29:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's Gym RR LM Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-13 Client Sample ID: 24-163.G13  
Collection Date: 1/16/2025 5:30:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's Gym RR RM Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-14 Client Sample ID: 24-163.G14  
Collection Date: 1/16/2025 5:30:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's Gym R Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-15 Client Sample ID: 24-163.G15  
Collection Date: 1/16/2025 5:31:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Hall DF at Gym/Boy's RR

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-16 Client Sample ID: 24-163.G16  
Collection Date: 1/16/2025 5:32:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's Gym RR L Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-17 Client Sample ID: 24-163.G17  
Collection Date: 1/16/2025 5:33:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's Gym RR LM Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-18 Client Sample ID: 24-163.G18  
Collection Date: 1/16/2025 5:34:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's Gym RR RM Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-19 Client Sample ID: 24-163.G19  
Collection Date: 1/16/2025 5:34:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's Gym RR Rt Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-20 Client Sample ID: 24-163.G20  
Collection Date: 1/16/2025 5:35:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Hall DF at Gym/Girl's RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-21 Client Sample ID: 24-163.G21  
Collection Date: 1/16/2025 5:35:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Hall DF Bottle Fill at Girl's RR

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-22 Client Sample ID: 24-163.G22  
Collection Date: 1/16/2025 5:56:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's Locker L Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-23 Client Sample ID: 24-163.G24  
Collection Date: 1/16/2025 5:55:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's Locker R Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-24 Client Sample ID: 24-163.G25  
Collection Date: 1/16/2025 5:57:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's Locker DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-25 Client Sample ID: 24-163.G27  
Collection Date: 1/16/2025 5:58:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's Locker L Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.621		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-26 Client Sample ID: 24-163.G29  
Collection Date: 1/16/2025 5:58:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's Locker R Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.49		0.512	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-27 Client Sample ID: 24-163.G30  
Collection Date: 1/16/2025 5:58:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's Locker DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.21		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-28 Client Sample ID: 24-163.G32  
Collection Date: 1/16/2025 5:59:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Small Gym DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-29 Client Sample ID: 24-163.G33  
Collection Date: 1/16/2025 5:59:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Small Gym DF Bottle Fill

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-30 Client Sample ID: 24-163.G34  
Collection Date: 1/16/2025 6:03:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Shop L Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.03		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-31 Client Sample ID: 24-163.G35  
Collection Date: 1/16/2025 6:03:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Shop M Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.45		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-32 Client Sample ID: 24-163.G36  
Collection Date: 1/16/2025 6:03:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Shop R Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.13		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-33 Client Sample ID: 24-163.G37  
Collection Date: 1/16/2025 6:05:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 212 Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.45		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-34 Client Sample ID: 24-163.G38  
Collection Date: 1/16/2025 6:07:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 211 Front Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.93		0.515	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-35 Client Sample ID: 24-163.G39  
Collection Date: 1/16/2025 6:07:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 211 Back Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	21.7	*	0.500	ppb	1	1/24/2025	15.0	A

Lab ID: 25010677-36 Client Sample ID: 24-163.G40  
Collection Date: 1/16/2025 6:08:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boiler Rm Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.616		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677

Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

**Lab Order:** 25010677  
**Received Date:** 1/16/2025 3:05:00 PM  
**Reported Date:** 1/29/2025 3:03:31 PM

Sample Information:

**Lab ID:** 25010677-37 **Client Sample ID:** 24-163.G41  
**Collection Date:** 1/16/2025 6:11:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Staff Hall RR Rm 112 L Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A	

**Lab ID:** 25010677-38 **Client Sample ID:** 24-163.G42  
**Collection Date:** 1/16/2025 6:12:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Staff Hall RR Rm 112 M Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.820		0.515	ppb	1	1/27/2025	15.0	A	

**Lab ID:** 25010677-39 **Client Sample ID:** 24-163.G43  
**Collection Date:** 1/16/2025 6:13:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Staff Hall RR Rm 112 R Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.643		0.515	ppb	1	1/27/2025	15.0	A	

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677

Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

**Lab Order:** 25010677  
**Received Date:** 1/16/2025 3:05:00 PM  
**Reported Date:** 1/29/2025 3:03:31 PM

Sample Information:

**Lab ID:** 25010677-40 **Client Sample ID:** 24-163.G44  
**Collection Date:** 1/16/2025 6:14:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Girl's Hall RR Rm 112 L Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

**Lab ID:** 25010677-41 **Client Sample ID:** 24-163.G45  
**Collection Date:** 1/16/2025 6:14:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Girl's Hall RR Rm 112 LM Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

**Lab ID:** 25010677-42 **Client Sample ID:** 24-163.G46  
**Collection Date:** 1/16/2025 6:16:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Girl's Hall RR Rm 112 RM Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677

Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

**Lab Order:** 25010677  
**Received Date:** 1/16/2025 3:05:00 PM  
**Reported Date:** 1/29/2025 3:03:31 PM

Sample Information:

**Lab ID:** 25010677-43 **Client Sample ID:** 24-163.G47  
**Collection Date:** 1/16/2025 6:17:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Girl's Hall RR Rm 112 R Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

**Lab ID:** 25010677-44 **Client Sample ID:** 24-163.G48  
**Collection Date:** 1/16/2025 6:18:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Hall DF at Rm 112

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/27/2025	15.0	A

**Lab ID:** 25010677-45 **Client Sample ID:** 24-163.G49  
**Collection Date:** 1/16/2025 6:21:00 AM **Collected By:** Mark Kasper  
**Matrix:** Drinking Water **Sample Location:** Rm 209 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.51		0.515	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

**NELAP** NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-46 Client Sample ID: 24-163.G50  
Collection Date: 1/16/2025 6:20:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Chem Rm at Rm 209 L Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-47 Client Sample ID: 24-163.G51  
Collection Date: 1/16/2025 6:20:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Chem Rm at Rm 209 R Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-48 Client Sample ID: 24-163.G52  
Collection Date: 1/16/2025 6:15:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 210 L Lab Sink at Door

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.511		0.500	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-49 Client Sample ID: 24-163.G53  
Collection Date: 1/16/2025 6:16:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 210 M Lab Sink at Door

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-50 Client Sample ID: 24-163.G54  
Collection Date: 1/16/2025 6:16:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 210 L Lab Sink at Door

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-51 Client Sample ID: 24-163.G55  
Collection Date: 1/16/2025 6:16:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 210 L Lab Sink at Courtyard

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-52 Client Sample ID: 24-163.G56  
Collection Date: 1/16/2025 6:16:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 210 M Lab Sink at Courtyard

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.500	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-53 Client Sample ID: 24-163.G57  
Collection Date: 1/16/2025 6:16:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 210 R Lab Sink at Courtyard

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-54 Client Sample ID: 24-163.G58  
Collection Date: 1/16/2025 6:16:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 210 Lab Sink Teacher Desk

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.95		0.500	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-55 Client Sample ID: 24-163.G59  
Collection Date: 1/16/2025 6:26:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 208 L Lab Sink at Door

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.50		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-56 Client Sample ID: 24-163.G60  
Collection Date: 1/16/2025 6:26:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 208 R Lab Sink at Door

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-57 Client Sample ID: 24-163.G61  
Collection Date: 1/16/2025 6:28:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 208 L Lab Sink at Hall

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-58 Client Sample ID: 24-163.G62  
Collection Date: 1/16/2025 6:28:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 208 R Lab Sink at Hall

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-59 Client Sample ID: 24-163.G63  
Collection Date: 1/16/2025 6:28:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 208 L Lab Sink at Courtyard

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-60 Client Sample ID: 24-163.G64  
Collection Date: 1/16/2025 6:28:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 208 R Lab Sink at Courtyard

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.94		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-61 Client Sample ID: 24-163.G65  
Collection Date: 1/16/2025 6:28:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 208 R Lab Sink at Teacher Desk

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	27.0	*	0.500	ppb	1	1/24/2025	15.0	A

Lab ID: 25010677-62 Client Sample ID: 24-163.G66  
Collection Date: 1/16/2025 6:28:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Storage Rm Sink at Rm 208

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.526		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-63 Client Sample ID: 24-163.G67  
Collection Date: 1/16/2025 6:30:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 207 L Lab Sink at Door

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.877		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-64 Client Sample ID: 24-163.G68  
Collection Date: 1/16/2025 6:30:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 207 R Lab Sink at Door

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-65 Client Sample ID: 24-163.G69  
Collection Date: 1/16/2025 6:31:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 207 Lab Sink at Teacher Desk

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	11.2		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-66 Client Sample ID: 24-163.G70  
Collection Date: 1/16/2025 6:32:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 207 L Lab Sink at Courtyard

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.32		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-67 Client Sample ID: 24-163.G71  
Collection Date: 1/16/2025 6:32:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 207 R Lab Sink at Courtyard

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.07		0.500	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-68 Client Sample ID: 24-163.G72  
Collection Date: 1/16/2025 6:32:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 207 L Lab Sink R Wall

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.23		0.500	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-69 Client Sample ID: 24-163.G73  
Collection Date: 1/16/2025 6:33:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 207 R Lab Sink R Wall

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.20		0.500	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-70 Client Sample ID: 24-163.G74  
Collection Date: 1/16/2025 6:35:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 205 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.06		0.500	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-71 Client Sample ID: 24-163.G75  
Collection Date: 1/16/2025 6:35:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Storage Rm Sink at Rm 205

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/27/2025	15.0	A

Lab ID: 25010677-72 Client Sample ID: 24-163.G76  
Collection Date: 1/16/2025 6:37:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Rm 206 Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KN	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.500	ppb	1	1/27/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-73 Client Sample ID: 24-163.G77  
Collection Date: 1/16/2025 6:40:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Office Staff Rm Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.33		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-74 Client Sample ID: 24-163.G78  
Collection Date: 1/16/2025 6:41:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Hall DF at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-75 Client Sample ID: 24-163.G79  
Collection Date: 1/16/2025 6:48:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's RR L Sink at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.831		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-76 Client Sample ID: 24-163.G80  
Collection Date: 1/16/2025 6:49:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's RR LM Sink at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-77 Client Sample ID: 24-163.G81  
Collection Date: 1/16/2025 6:48:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's RR RM Sink at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-78 Client Sample ID: 24-163.G82  
Collection Date: 1/16/2025 6:48:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Girl's RR R Sink at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.645		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-79 Client Sample ID: 24-163.G83  
Collection Date: 1/16/2025 6:50:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's RR L Sink at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-80 Client Sample ID: 24-163.G84  
Collection Date: 1/16/2025 6:50:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's RR M Sink at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-81 Client Sample ID: 24-163.G85  
Collection Date: 1/16/2025 6:50:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Boy's RR R Sink at Rm 100

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-82 Client Sample ID: 24-163.G86  
Collection Date: 1/16/2025 6:55:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Library Side Rm Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-83 Client Sample ID: 24-163.G87  
Collection Date: 1/16/2025 7:00:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Room 405 (Portable) L Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.824		0.515	ppb	1	1/28/2025	15.0	A

Lab ID: 25010677-84 Client Sample ID: 24-163.G88  
Collection Date: 1/16/2025 7:00:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Room 405 (Portable) M Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: KN
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.576		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Analytical Report

WO#: 25010677  
Date Reported: 1/29/2025

Coleman Creek Consulting  
810 Leonard St  
Ashland, OR 97520

Lab Order: 25010677  
Received Date: 1/16/2025 3:05:00 PM  
Reported Date: 1/29/2025 3:03:31 PM

Sample Information:

Lab ID: 25010677-85 Client Sample ID: 24-163.G89  
Collection Date: 1/16/2025 7:00:00 AM Collected By: Mark Kasper  
Matrix: Drinking Water Sample Location: Room 405 (Portable) R Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KN		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	1/28/2025	15.0	A

QUALIFIERS	*	Value exceeds Maximum or Minimum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcod
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	PRE	Percent RE exceeds the Limit	R	RPD outside accepted recovery limits

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original

Results are out of the EPA limits



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

Client: Coleman Creek Consulting  
Project: 24-163G Henley HS

TestCode: LEAD\_DW

Sample ID: <b>MB-30009</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/24/2025</b>	RunNo: <b>55735</b>
Client ID: <b>PBW</b>	Batch ID: <b>30009</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/24/2025</b>	SeqNo: <b>921049</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.500			
------	----	-------	--	--	--

Sample ID: <b>LCS-30009</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/24/2025</b>	RunNo: <b>55735</b>
Client ID: <b>LCSW</b>	Batch ID: <b>30009</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/24/2025</b>	SeqNo: <b>921050</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	102	0.500	100	0	102	85	115			
------	-----	-------	-----	---	-----	----	-----	--	--	--

Sample ID: <b>25010675-60AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/24/2025</b>	RunNo: <b>55735</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>30009</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/24/2025</b>	SeqNo: <b>921052</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	96.7	0.500	100	0.0860	96.6	70	130			
------	------	-------	-----	--------	------	----	-----	--	--	--

Sample ID: <b>25010675-60AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/24/2025</b>	RunNo: <b>55735</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>30009</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/24/2025</b>	SeqNo: <b>921053</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	95.3	0.500	100	0.0860	95.2	70	130	96.7	1.40	20
------	------	-------	-----	--------	------	----	-----	------	------	----

Qualifiers:	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceeds
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit
	RL Reporting Detection Limit		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

Client: Coleman Creek Consulting  
Project: 24-163G Henley HS

TestCode: LEAD\_DW

Sample ID: <b>MB-30034</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>PBW</b>	Batch ID: <b>30034</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921806</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.500			
------	----	-------	--	--	--

Sample ID: <b>LCS-30034</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>LCSW</b>	Batch ID: <b>30034</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921807</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	101	0.500	100	0	101	85	115			
------	-----	-------	-----	---	-----	----	-----	--	--	--

Sample ID: <b>25010902-01AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>30034</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921817</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	99.9	0.500	100	1.85	98.0	70	130			
------	------	-------	-----	------	------	----	-----	--	--	--

Sample ID: <b>25010902-01AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>30034</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921818</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	99.3	0.500	100	1.85	97.4	70	130	99.9	0.573	20
------	------	-------	-----	------	------	----	-----	------	-------	----

Qualifiers:	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceeds
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit
	RL Reporting Detection Limit		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

Client: Coleman Creek Consulting  
Project: 24-163G Henley HS

TestCode: LEAD\_DW

Sample ID: <b>MB-30030</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>PBW</b>	Batch ID: <b>30030</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921823</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.515			
------	----	-------	--	--	--

Sample ID: <b>LCS-30030</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>LCSW</b>	Batch ID: <b>30030</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921824</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	99.9	0.520	100	0	99.9 85 115
------	------	-------	-----	---	-------------

Sample ID: <b>25010670-44AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>30030</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921826</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	104	0.520	100	7.93	96.1 70 130
------	-----	-------	-----	------	-------------

Sample ID: <b>25010670-44AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>30030</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921827</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	103	0.520	100	7.93	95.2 70 130 104 0.925 20
------	-----	-------	-----	------	--------------------------

Qualifiers:	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceeds
	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit
	RL Reporting Detection Limit		

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

**Client:** Coleman Creek Consulting  
**Project:** 24-163G Henley HS

**TestCode:** LEAD\_DW

Sample ID: <b>MB-30031</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>PBW</b>	Batch ID: <b>30031</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921851</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: <b>LCS-30031</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>LCSW</b>	Batch ID: <b>30031</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921852</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 102 0.520 100 0 102 85 115

Sample ID: <b>25010677-06AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>24-163.G6</b>	Batch ID: <b>30031</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921854</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 97.8 0.520 100 0 97.8 70 130

Sample ID: <b>25010677-06AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>24-163.G6</b>	Batch ID: <b>30031</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921855</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 97.6 0.520 100 0 97.6 70 130 97.8 0.127 20

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeds  
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit PL Permit Limit  
RL Reporting Detection Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

Client: Coleman Creek Consulting  
Project: 24-163G Henley HS

TestCode: LEAD\_DW

Sample ID: <b>MB-30032</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>PBW</b>	Batch ID: <b>30032</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921879</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	ND	0.515			

Sample ID: <b>LCS-30032</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>LCSW</b>	Batch ID: <b>30032</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921880</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	101	0.520	100	0	101 85 115

Sample ID: <b>25010677-26AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>24-163.G29</b>	Batch ID: <b>30032</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921882</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	101	0.520	100	2.49	99.0 70 130

Sample ID: <b>25010677-26AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/27/2025</b>	RunNo: <b>55771</b>
Client ID: <b>24-163.G29</b>	Batch ID: <b>30032</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/27/2025</b>	SeqNo: <b>921883</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead	102	0.520	100	2.49	99.1 70 130 101 0.188 20

Qualifiers: \* Value exceeds Maximum or Minimum Contaminant Level.  
MI Recovery outside control limits due to Matrix Interference  
RL Reporting Detection Limit

CI Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeds  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

**Client:** Coleman Creek Consulting  
**Project:** 24-163G Henley HS

**TestCode:** LEAD\_DW

Sample ID: <b>MB-30052</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>
Client ID: <b>PBW</b>	Batch ID: <b>30052</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922292</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: <b>MB-30049</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>
Client ID: <b>PBW</b>	Batch ID: <b>30049</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922295</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.500

Sample ID: <b>LCS-30049</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>
Client ID: <b>LCSW</b>	Batch ID: <b>30049</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922296</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 101 0.500 100 0 101 85 115

Sample ID: <b>25010939-01BMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>
Client ID: <b>BatchQC</b>	Batch ID: <b>30049</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922298</b>
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 97.6 0.500 100 0.799 96.8 70 130

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level. C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeds  
MI Recovery outside control limits due to Matrix Interference ND Not Detected at the Reporting Limit PL Permit Limit  
RL Reporting Detection Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

**Client:** Coleman Creek Consulting  
**Project:** 24-163G Henley HS

**TestCode:** LEAD\_DW

Sample ID: <b>25010939-01BMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>BatchQC</b>	Batch ID: <b>30049</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922299</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.6	0.500	100	0.799	95.8	70	130	97.6	1.02	20	

Sample ID: MB-30051	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 1/28/2025	RunNo: 55798						
Client ID: PBW	Batch ID: 30051	TestNo: E200.8	E200.8	Analysis Date: 1/28/2025	SeqNo: 922313						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									

Sample ID: <b>MB-30051</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>PBW</b>	Batch ID: <b>30051</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922314</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.515									


Sample ID: <b>LCS-30051</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>30051</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922315</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	96.2	0.520	100	0	96.2	85	115				

**Qualifiers:** \* Value exceeds Maximum or Minimum Contaminant Level.  
MI Recovery outside control limits due to Matrix Interference  
RL Reporting Detection Limit

CI Sample container temperature is out of limit as specified at testcode  
ND Not Detected at the Reporting Limit

H Holding times for preparation or analysis exceeds  
PL Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

Client: Coleman Creek Consulting  
Project: 24-163G Henley HS

TestCode: LEAD\_DW

Sample ID: <b>LCS-30051</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>30051</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922316</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	96.3	0.520	100	0	96.3	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: <b>25010677-55AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>24-163.G59</b>	Batch ID: <b>30051</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922318</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	187	0.520	200	1.50	92.8	70	130				
------	-----	-------	-----	------	------	----	-----	--	--	--	--

Sample ID: <b>25010677-55AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>24-163.G59</b>	Batch ID: <b>30051</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922319</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	190	0.520	200	1.50	94.1	70	130	187	1.38	20	
------	-----	-------	-----	------	------	----	-----	-----	------	----	--

Sample ID: <b>MB-30052</b>	SampType: <b>MBLK</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>PBW</b>	Batch ID: <b>30052</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922327</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.515									
------	----	-------	--	--	--	--	--	--	--	--	--

**Qualifiers:**

*	Value exceeds Maximum or Minimum Contaminant Level.
MI	Recovery outside control limits due to Matrix Interference
RL	Reporting Detection Limit

CI	Sample container temperature is out of limit as specified at testcode
ND	Not Detected at the Reporting Limit

H	Holding times for preparation or analysis exceeds
PL	Permit Limit

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## QC SUMMARY REPORT

WO#: 25010677  
29-Jan-25

**Client:** Coleman Creek Consulting  
**Project:** 24-163G Henley HS

**TestCode:** LEAD\_DW

Sample ID: <b>LCS-30052</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>30052</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922328</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.2	0.520	100	0	97.2	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: <b>LCS-30052</b>	SampType: <b>LCS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>30052</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922329</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	97.4	0.520	100	0	97.4	85	115				
------	------	-------	-----	---	------	----	-----	--	--	--	--

Sample ID: <b>25010677-82AMS</b>	SampType: <b>MS</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>24-163.G86</b>	Batch ID: <b>30052</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922331</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual


Lead	186	0.520	200	0.171	92.7	70	130				
------	-----	-------	-----	-------	------	----	-----	--	--	--	--

Sample ID: <b>25010677-82AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>LEAD_DW</b>	Units: <b>ppb</b>	Prep Date: <b>1/28/2025</b>	RunNo: <b>55798</b>						
Client ID: <b>24-163.G86</b>	Batch ID: <b>30052</b>	TestNo: <b>E200.8</b>	<b>E200.8</b>	Analysis Date: <b>1/28/2025</b>	SeqNo: <b>922332</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	180	0.520	200	0.171	89.8	70	130	186	3.16	20	
------	-----	-------	-----	-------	------	----	-----	-----	------	----	--

<b>Qualifiers:</b>	* Value exceeds Maximum or Minimum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	H Holding times for preparation or analysis exceeds
MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit	PL Permit Limit	
RL Reporting Detection Limit			

Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

## Sample Log-In Check List

Client Name: **ColemanCreek**

Work Order Number: **25010677**

RcptNo: **1**

Logged by: **Ashley Spiegelberg** **1/16/2025 3:05:00 PM**

Completed By: **Danielle Garten** **1/20/2025 9:15:52 AM**

Reviewed By: **Tamra Schmedemann** **1/29/2025 2:44:57 PM**

*Am*  
*Danielle Garten*  
*Tamra Schmedemann*

### Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐  
2. How was the sample delivered? Client

### Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒  
4. Shipping container/cooler in good condition? Yes ☒ No ☐  
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒ NA ☐  
No. Seal Date: Signed By:  
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒  
6. Were all samples received at a temperature of  $>0^{\circ}\text{C}$  to  $6.0^{\circ}\text{C}$ ? Yes ☐ No ☐ NA ☒  
7. Sample(s) in proper container(s)? Yes ☒ No ☐  
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐  
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐  
10. Was preservative added to bottles? Yes ☐ No ☒ NA ☐  
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒  
12. Were any sample containers received broken? Yes ☐ No ☒  
13. Does paperwork match bottle labels?  
(Note discrepancies on chain of custody) Yes ☒ No ☐  
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐  
15. Is it clear what analyses were requested? Yes ☒ No ☐  
16. Were all holding times able to be met?  
(If no, notify customer for authorization.) Yes ☒ No ☐

### Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒


Person Notified:  Date:   
By Whom:  Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person  
Regarding:   
Client Instructions:

18. Additional remarks:

### Cooler Information

Cooler No	Temp $^{\circ}\text{C}$	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	-------------------------	-----------	-------------	---------	-----------	-----------





# Coleman Creek Consulting, Inc.

Dave 944-5318


## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME	Lab ID
24-163G.1	DW	Kitchen Bath Sink Faucet	5:09	01
24-163G.2	DW	Kitchen Sink Faucet, Exterior Wall Left	5:11	02
24-163G.3	DW	Kitchen Sink Faucet, Staff Room Wall, Left Right	5:13	03
24-163G.4	DW	Kitchen Sink Faucet, Staff Room Wall, Right Hand Wash	5:15	04
24-163G.5	DW	Cafeteria Drinking Fountain	5:17	05
24-163G.6	DW	Cafeteria Drinking Fountain Bottle Fill	5:17	06
24-163G.7	DW	Back of Main Gym Drinking Fountain	5:22	07
24-163G.8	DW	Main Gym Corner Drinking Fountain	5:24	08
24-163G.9	DW	Main Gym Corner Drinking Fountain Bottle Fill	5:26	09
24-163G.10	DW	Gym Concession Left Sink Faucet	5:28	10
24-163G.11	DW	Boy's Gym Restroom Left Sink Faucet	5:29	11
24-163G.12	DW	Boy's Gym Restroom Left Middle Sink Faucet	5:29	12
24-163G.13	DW	Boy's Gym Restroom Right Middle Faucet	5:30	13
24-163G.14	DW	Boy's Gym Restroom Right Sink Faucet	5:30	14
24-163G.15	DW	Hall Drinking Fountain at Gym/Boy's Bath	5:31	15
24-163G.16	DW	Girl's Gym Restroom Left Sink Faucet	5:33	16
24-163G.17	DW	Girl's Gym Restroom Left Middle Sink Faucet	5:33	17
24-163G.18	DW	Girl's Gym Restroom Right Middle Faucet	5:34	18
24-163G.19	DW	Girl's Gym Restroom Right Sink Faucet	5:34	19
24-163G.20	DW	Hall Drinking Fountain at Gym/Girl's Bath	5:35	20

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.

## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME	
24-163G.21	DW	Hall Drinking Fountain Bottle Fill at Girl's Bath	5:35	21
24-163G.22	DW	Boy's Locker Left Sink Faucet	5:56	22
<del>24-163G.23</del>	<del>DW</del>	<del>Boy's Locker Middle Sink Faucet</del>		
24-163G.24	DW	Boy's Locker Right Sink Faucet	5:55	23
24-163G.25	DW	Boy's Locker Drinking Fountain	5:57	24
<del>24-163G.26</del>	<del>DW</del>	<del>Boy's Locker Drinking Fountain Bottle Fill</del>		
24-163G.27	DW	Girl's Locker Left Sink Faucet	5:58	25
<del>24-163G.28</del>	<del>DW</del>	<del>Girl's Locker Middle Sink Faucet</del>		
24-163G.29	DW	Girl's Locker Right Sink Faucet	5:58	26
24-163G.30	DW	Girl's Locker Drinking Fountain	5:58	27
<del>24-163G.31</del>	<del>DW</del>	<del>Girl's Locker Drinking Fountain Bottle Fill</del>	<del>5:58</del>	
24-163G.32	DW	Small Gym Drinking Fountain	5:59	28
24-163G.33	DW	Small Gym Drinking Fountain Bottle Fill	5:59	29
24-163G.34	DW	Shop Left Sink Faucet	6:03	30
24-163G.35	DW	Shop Middle Sink Faucet	6:03	31
24-163G.36	DW	Shop Right Sink Faucet	6:03	32
24-163G.37	DW	Room 212 Sink Faucet	6:05	33
24-163G.38	DW	Room 211 Front Sink Faucet	6:07	34
24-163G.39	DW	Room 211 Back Sink Faucet	6:07	35
24-163G.40	DW	Boiler Room Sink Faucet	6:08	36

No  
No  
No  
No

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.

## DRINKING WATER SITE SAMPLE RECORD SHEET


BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME
24-163G.41	DW	Staff Hall Bath at Room 112 Left Sink Faucet	6/1
24-163G.42	DW	Staff Hall Bath at Room 112 Middle Sink Faucet	6/12
24-163G.43	DW	Staff Hall Bath at Room 112 Right Sink Faucet	6/13
24-163G.44	DW	Girl's Hall Bath at Room 112 Left Sink Faucet	6/14
24-163G.45	DW	Girl's Hall Bath at Room 112 LM Sink Faucet	6/14
24-163G.46	DW	Girl's Hall Bath at Room 112 RM Sink Faucet	6/16
24-163G.47	DW	Girl's Hall Bath at Room 112 Right Sink Faucet	6/17
24-163G.48	DW	Hall Drinking Fountain at Room 112	6/18
24-163G.49	DW	Room 209 Sink Faucet	
24-163G.50	DW	Chemical Room at Room 209, Left Sink Faucet	
24-163G.51	DW	Chemical Room at Room 209, Right Sink Faucet	
24-163G.52	DW	Room 210 Left Lab Sink Faucet at Door	
24-163G.53	DW	Room 210 Middle Lab Sink Faucet at Door	
24-163G.54	DW	Room 210 Left Lab Sink Faucet at Door	
24-163G.55	DW	Room 210 Left Lab Sink Faucet at Courtyard	
24-163G.56	DW	Room 210 Middle Lab Sink Faucet at Courtyard	
24-163G.57	DW	Room 210 Right Lab Sink Faucet at Courtyard	
24-163G.58	DW	Room 210 Lab Sink Faucet at Teacher Desk	
24-163G.59	DW	Room 208 Left Lab Sink Faucet at Door	
24-163G.60	DW	Room 208 Right Lab Sink Faucet at Door	

37  
38  
39  
40  
41  
42  
43  
44

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.

Dave 944-5318

## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME	
24-163G.41	DW	Staff Hall Bath at Room 112 Left Sink Faucet		
24-163G.42	DW	Staff Hall Bath at Room 112 Middle Sink Faucet		
24-163G.43	DW	Staff Hall Bath at Room 112 Right Sink Faucet		
24-163G.44	DW	Girl's Hall Bath at Room 112 Left Sink Faucet		
24-163G.45	DW	Girl's Hall Bath at Room 112 LM Sink Faucet		
24-163G.46	DW	Girl's Hall Bath at Room 112 RM Sink Faucet		
24-163G.47	DW	Girl's Hall Bath at Room 112 Right Sink Faucet		
24-163G.48	DW	Hall Drinking Fountain at Room 112		
24-163G.49	DW	Room 209 Sink Faucet	621	45
24-163G.50	DW	Chemical Room at Room 209, Left Sink Faucet	620	46
24-163G.51	DW	Chemical Room at Room 209, Right Sink Faucet	620	47
24-163G.52	DW	Room 210 Left Lab Sink Faucet at Door	615	48
24-163G.53	DW	Room 210 Middle Lab Sink Faucet at Door	616	49
24-163G.54	DW	Room 210 Left Lab Sink Faucet at Door	616	50
24-163G.55	DW	Room 210 Left Lab Sink Faucet at Courtyard	616	51
24-163G.56	DW	Room 210 Middle Lab Sink Faucet at Courtyard	616	52
24-163G.57	DW	Room 210 Right Lab Sink Faucet at Courtyard	616	53
24-163G.58	DW	Room 210 Lab Sink Faucet at Teacher Desk	616	54
24-163G.59	DW	Room 208 Left Lab Sink Faucet at Door	626	55
24-163G.60	DW	Room 208 Right Lab Sink Faucet at Door	626	56

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.


## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME	
24-163G.61	DW	Room 208 Left Lab Sink Faucet at Hall Wall	6:28	57
24-163G.62	DW	Room 208 Right Lab Sink Faucet at Hall Wall	6:28	58
24-163G.63	DW	Room 208 Left Lab Sink Faucet at Courtyard Wall	6:28	59
24-163G.64	DW	Room 208 Right Lab Sink Faucet at Courtyard	6:28	60
24-163G.65	DW	Room 208 Right Lab Sink Faucet at Teacher Desk	6:28	61
24-163G.66	DW	Storage Room Sink Faucet at Room 208	6:28	62
24-163G.67	DW	Room 207 Left Lab Sink Faucet at Door	6:30	63
24-163G.68	DW	Room 207 Right Lab Sink Faucet at Door	6:30	64
24-163G.69	DW	Room 207 Lab Sink Faucet at Teacher Desk	6:31	65
24-163G.70	DW	Room 207 Left Lab Sink Faucet at Courtyard Wall	6:32	66
24-163G.71	DW	Room 207 Right Lab Sink Faucet at Courtyard	6:32	67
24-163G.72	DW	Room 207 Left Lab Sink Faucet at Right Wall	6:32	68
24-163G.73	DW	Room 207 Right Lab Sink Faucet at Right Wall	6:33	69
24-163G.74	DW	Room 205 Sink Faucet	6:35	70
24-163G.75	DW	Storage Room Sink Faucet at Room 205	6:35	71
24-163G.76	DW	Room 206 Sink Faucet	6:37	72
24-163G.77	DW	Office Staff Room Sink Faucet	6:40	73
24-163G.78	DW	Hall Drinking Fountain at Room 100	6:41	74
24-163G.79	DW	Girl's Bath Left Sink Faucet at Room 100	6:41	75
24-163G.80	DW	Girl's Bath Left Middle Sink Faucet at Room 100	6:44	76

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle



# Coleman Creek Consulting, Inc.

## DRINKING WATER SITE SAMPLE RECORD SHEET

BUILDING: Henley High School  
ADDRESS: 8245 Hwy. 39  
Klamath Falls, Oregon

DATE: 01-16-25  
SAMPLER: Mark Kasper

SAMPLE #	SAMPLE TYPE	LOCATION	TIME	
24-163G.81	DW	Girl's Bath Right Middle Sink Faucet at Room 100	6:48	77
24-163G.82	DW	Girl's Bath Right Sink Faucet at Room 100	6:48	78
24-163G.83	DW	Boy's Bath Left Sink Faucet at Room 100	6:50	79
24-163G.84	DW	Boy's Bath Middle Sink Faucet at Room 100	6:50	80
24-163G.85	DW	Boy's Bath Right Sink Faucet at Room 100	6:50	81
24-163G.86	DW	Library Side Room Sink Faucet	6:55	82
24-163G.87	DW	Room 405 (Portable) Left Sink Faucet	7:00	83
24-163G.88	DW	Room 405 (Portable) Middle Sink Faucet	7:00	84
24-163G.89	DW	Room 405 (Portable) Right Sink Faucet	7:00	85

Comments: DW = Drinking Water RR = Restroom R = Right L = Left RM = Right Middle  
LM = Left Middle M = Middle

- 
- A Total Alkalinity and Bicarbonate Alkalinity results are to a pH endpoint of 4.5. Carbonate Alkalinity result is to a pH endpoint of 8.3.
- A-LL The total low level alkalinity results are to a pH endpoint of 4.3-4.7 pH units per SM 2320 B.
- B Analyte detected in the associated method blank.
- C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
- C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
- CF Results confirmed by re-analysis.
- CU Cleanup performed as specified by method.
- E Estimated value.
- ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
- FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
- HP Sample re-analysis performed outside of method specified holding time.
- HR Sample received outside of method specified holding time.
- HS Sample analyzed for volatile organics contained headspace.
- HT At the client's request, the sample was analyzed outside of method specified holding time.
- H Analysis performed outside of method specified holding time.
- J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
- L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
- MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
- N See Case Narrative on page 2 of report.
- Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS), and/or matrix spikes exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
- R Relative percent difference (RPD) is outside of the accepted recovery limits.
- R1 The numerical difference between the parent sample and the duplicate (DUP) is outside of the accepted recovery limits. Greater than 5 degrees for Flashpoint, or greater than 0.1 pH units for pH.
- R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
- R4 The Relative percent difference (RPD) is not within control limits because the concentration of the sample result is too low to represent proper statistical error.
- R5 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30% because the results are too low to represent proper statistical error. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series. The sample results are not affected.
- R6 The difference between the BOD/CBOD results for the highest and lowest dilution used for the calculation is >30%. This may indicate a possible matrix interference. The BOD/CBOD sample result is an average of all qualified bottles for each dilution series.
- S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
- S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
- SC Sub-contracted to another laboratory for analysis.
- SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
- \* Value exceeds Maximum Contaminant Level or is outside the acceptable range.<<>>
- 1 Value exceeds one half of the Maximum Contaminant Level.